

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

Este informe contiene información muy importante sobre su agua potable.  
 Tradúzcalo o hable con alguien que lo entienda bien.

**Monitoring Requirements Not Met for  
 CSP Hollister Hills SVRA – Water System No. 3510302**

Our water system failed to monitor as required for drinking water standards during the past year and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During August 2010, we did not sample for coliform from the distribution system and therefore, cannot be sure of the quality of our drinking water during that time.*

**What should I do?**

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the last year, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

<i>Contaminant</i>	<i>Required Sampling Frequency</i>	<i>Number of Samples Taken</i>	<i>When All Samples Should Have Been Taken</i>	<i>When Samples Were or Will Be Taken</i>
Coliform	Two (2) samples per month	0	During August 2010	Sampled September 28, 2010

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

July 14, 2011

Citation No. 02-05-10C-033  
CSP Hollister Hills SVRA  
Attachment A

### **What happened? What is being done?**

During the month of August 2010 water system No.3510302 incurred numerous and continuous breaches within the distribution system resulting in the loss of over 250,000 gallons of water. Due to the ongoing repairs made as these breaches occurred all comfort stations were closed and signed stating no water was available. Portable comfort stations with hand washing capabilities were supplied and maintained via outside contractors throughout the park. While making continuous repairs and trying to refill storage facilities via a 18 gpm main well. The water system operator in charge failed to take the required coliform samples for the sampling period of August 2010. We have since taken the required samples, as described in the last column of the table above and therefore complied with monthly distribution sampling. However, we failed to collect 'special' coliform samples after system repairs and the sampling period for this compliance has since expired. The subsequent samples showed that we are meeting drinking water standards.

For more information, please contact Casimiro Rodriguez at 831-637-8714 or 7724 Cienega Road Hollister Ca. 95023.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

### **Secondary Notification Requirements**

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by CSP Hollister Hills SVRA water system.

State Water System ID#: 3510302

Date distributed: 7/14/2011

Water System Representative Name & Title: Matthew Allen, Park Maintenance Chief

Water System Representative Signature: \_\_\_\_\_

