

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
 Tradúzcalo o hable con alguien que lo entienda bien.

**Bacteriological Monitoring & Reporting
 Requirements Not Met for
 CSP-Andrew Molera State Reserve - System #2710301**

Our water system failed to monitor the correct number of coliform samples in the drinking water supply during February 2014 and, therefore, was in violation of the state drinking water regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for bacteriological contaminants on a monthly basis. Results of this monitoring are an indicator of whether or not our drinking water meets health standards. On February 12, 2014, the CSP-Andrew Molera State Reserve water system collected one sample for coliform analysis testing. This sample tested positive for total coliform bacteria and negative for E. coli. The water system failed to collect four distribution repeat samples for coliform bacteria analysis testing and therefore, cannot be sure of the quality of our drinking water during that time. Subsequent bacteriological testing conducted on 3/12/14, shows that the CSP-Andrew Molera State Reserve is free of coliform bacteria and therefore, the water system has returned to compliance with bacteriological monitoring and reporting requirements.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the last year, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

<i>Contaminant</i>	<i>Required Sampling Frequency</i>	<i>Number of Samples Taken</i>	<i>When All Samples Should Have Been Taken</i>	<i>When Samples Were or Will Be Taken</i>
Coliform	One routine distribution sample every month & 4 repeat samples following any total coliform-positive result	One routine distribution sample on Feb. 12, 2014	Four repeat distribution samples following the total coliform-positive distribution sample collected on February 12, 2014	Five samples were collected on 3/12/14

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Follow up samples were collected and were absent of coliform bacteria.

For more information, please contact Marc Lewis at 831 667 2819 .

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by the CSP-Andrew Molera State Reserve

State Water System ID#: 2710301

Date distributed: 3/20/2014

System Representative Name & Title: Marc Lewis Water Plant Supervisor

Water System Representative Signature: 