

State of California
Department of Parks and Recreation

NOTICE OF EXEMPTION

TO: Office of Planning and Research
1400 Tenth Street
Sacramento, CA 95814

FROM: Department of Parks and Recreation
One Capitol Mall, Ste. 410
Sacramento, CA 95814

PROJECT TITLE: Water System Replacement

LOCATION: Hendy Woods State Park

COUNTY: Mendocino

DESCRIPTION OF THE NATURE AND PURPOSE OF PROJECT: Replace the 40-year old, deteriorated and leaking water distribution system at Hendy Woods State Park to provide reliable and adequate water supplies for park use and fire protection.

Tank Work will:

- Deconstruct and remove the existing 100,000 gallon redwood tank, store materials for future use
- Excavate, grade and compact an area 12 feet in diameter, fill and compact with 10 inches of aggregate to install two, 8 feet tall, temporary 5000 gallon HDPE water tanks and connect to the existing water system to supply the park during tank replacement
- Excavate an approximately 30 feet diameter, 3 feet wide and 4 feet deep for a concrete ring tank foundation and an approximately 2 feet deep by 3 feet square center concrete support to construct and install the new bolted steel 100,000 gallon water 24 feet tall storage tank on site at the same location as the old tank

Waterline Work will trench 3 feet deep by 3 feet wide and approximately:

- 3,400 feet in length from the existing well to the intersection of the campground access road and the main road to install 6" distribution and 4" conveyance pipes in a joint trench
- 810 feet in length from the main road along the tank access road to install a 6" and a 4" waterline and 2" electrical conduit in a joint trench spaced per guidelines
- 519 feet in length from the intersection of the access road and main road to the Wildcat Campground Loop road then the visitor center install a 6" and a 4" waterline and 2" electrical conduit in a joint trench spaced per guidelines

Waterline Work will trench 18 inches wide by 30 inches deep and approximately:

- 862 feet in length from the kiosk to the single residence along the service road to install 6" water line
- 438 feet in length from single residence to double residence along the service road to install a 6" waterline
- 265 feet in length from the double residence to the intersection of the service road and the main road to install a 6" water line
- 1626 feet in length from the south end of the service road to the tank access road to install 6" water line
- 2,000 feet in length to install a single 4" waterline and provide service to the Wildcat campground
- 2,258 feet in length to install a single 4" waterline and provide service to the Azalea Campground

Electrical Line work will trench 1 foot wide by 3 feet deep and approximately 260 feet in length from the intersection of the camp road and the Wildcat Campground Loop Road to the Visitor Center to install 2" electrical conduit to power the dosing pump house.

Lateral Lines work will excavate 1 foot wide by 2 feet deep and approximately (see below) to install up to 1 inch in diameter SCH 40 lateral water lines:

- ◆ 60 feet from the park road to the entrance kiosk
- ◆ 20 feet from the service road to the single residence
- ◆ 90 feet from the service road to the two residences
- ◆ 230 feet from the service road to the maintenance service yard
- ◆ 50 feet from the service road to the ranger station
- ◆ 40 feet from the Azalea Campground loop road to the northern restroom
- ◆ 20 feet from the Azalea Campground loop road to the eastern restroom
- ◆ 40 feet from the Wildcat Campground loop road to northern restroom
- ◆ 40 feet from the Wildcat Campground loop road to the Visitor Center
- ◆ 70 feet from the Wildcat Campground loop road to the southern restroom

Additional work will excavate up to 12" to place 3" of gravel base and a cement floor to construct a 4 feet x 4 feet x 8 feet high vented dosing pump house adjacent to the visitor center; remove and replace 10 hydrants and 32 faucet bibs in same locations and return all disturbed areas to pre-construction or better conditions.

DPR-approved standard project requirements have been incorporated into the Water System Improvement project. A list of project-specific project requirements can be viewed by contacting the environmental coordinator listed below.

PUBLIC AGENCY APPROVING THE PROJECT: California Department of Parks and Recreation

NAME OF DIVISION OR DISTRICT CARRYING OUT THE PROJECT: Acquisition & Development

EXEMPT STATUS:


Categorical Exemption Class: 1, 2, 3, 4 Section: 15301, 15302, 15303, 15304

REASONS WHY PROJECT IS EXEMPT: Project consists of the maintenance and repair of existing public facilities involving negligible expansion beyond current levels; replace existing structures where the new structure will be located in the same as the structure replaced and will have substantially the same purpose and capacity as the structure replaced, construction and location of limited numbers of new, small facilities and minor public alteration in the condition of land, which would not involve the removal of healthy, mature, scenic trees.

CONTACT: Patricia Du Mont
Northern Service Center

TELEPHONE: (916) 445-9081

EMAIL: Patricia.DuMont@parks.ca.gov


Kathy Amann, Deputy Director
Acquisition and Development

5/27/15
DATE

