



State of California – The Resources Agency
DEPARTMENT OF PARKS AND RECREATION

2018048237

NOTICE OF EXEMPTION

TO: Office of Planning and Research
1400 Tenth Street
Sacramento, CA 95814

FROM: Department of Parks and Recreation
Bay Area District
845 Casa Grande Road
Petaluma, CA 94954

PROJECT TITLE: East Peak Well

LOCATION: Mount Tamalpais State Park COUNTY: Marin

DESCRIPTION OF THE NATURE AND PURPOSE OF PROJECT: Install a new well at East Peak in Mount Tamalpais State Park to provide water for critical needs of the park. Work will:

- Drill a new 6 inch in diameter by 600 feet deep well in the East Peak parking lot;
- Install a well casing into the drilled hole and pump water out until the water runs clear;
- Test the water to ensure it meets public health code for human consumption;
- Install conduit and waterline over the surface of the ground from the new well head to Fern Creek Trail, then excavate a trench 8" wide x 24" deep x 24' long to run the conduit and waterline from Fern Creek Trail to the existing park waterline;
- Install a 6" x 8' x 8' concrete sanitary seal at well head;
- Construct a small 4' x 4' x 4' well house at the new well head for a disinfection pump and well vat; and
- Place large rocks in front of well house for protection and aesthetics.

PUBLIC AGENCY APPROVING THE PROJECT: California Department of Parks and Recreation

NAME OF DIVISION OR DISTRICT CARRYING OUT THE PROJECT: Bay Area District

EXEMPT STATUS:

Categorical Exemption Class: 3 & 4 Section: 15303 & 15304

REASONS WHY PROJECT IS EXEMPT:

Project consists of the construction and location of limited numbers of new, small facilities or structures; and minor public alterations in the condition of land which do not involve the removal of healthy, mature, scenic trees.

CONTACT: Cyndy Shafer
Bay Area District

PHONE NO.: (707) 769-5652 x 208
EMAIL: Cyndy.Shafer@parks.ca.gov



Vince Anibale, District Superintendent
Bay Area District

Governor's Office of Planning & Research

4-9-18

DATE

APR 10 2018

STATE CLEARINGHOUSE